

LITHIUM CELL/BATTERY TEST SUMMARY

IN ACCORDANCE WITH SUB-SECTION 38.3
OF MANUAL OF TESTS AND CRITERIA



N/A = Not Applicable

1. Name of cell / battery

74Wh Powerbank-20000mAh-PB320PD 74Wh

2. Manufacturer of cell / battery / product

Name	Ansmann AG
Address	Industriestr. 10, 97959 Assamstadt
Phone	+49 6294 4204-0
Email	info@ansmann.de
Website	www.ansmann.de

3. Test laboratory of cell / battery / product

Name	Shenzhen Poce Technology Co., Ltd.
Address	101-102, H5, Building & Floor 1, Hongfa Science Technology Park, Tangtou, Bao'an District, Shenzhen
Phone	+86 755 29113252
Email	service@poce-cert.com
Website	http://www.poce-cert.com

4. ID-number and date

Unique test report identification number	POCE211104003QRS-1	Date of test report	09.11.2021
--	--------------------	---------------------	------------

DESCRIPTION OF CELL / BATTERY

5. Mark the type of cell/battery with an "•"

<input type="radio"/> Lithium ion cell	<input type="radio"/> Lithium metal cell
<input checked="" type="radio"/> Lithium ion battery	<input type="radio"/> Lithium metal battery

6. Parameters

	Cell	Battery
Mass in gram (g):		414
Lithium ion: Indicate watt-hour rating (Wh):		74
Lithium metal: Indicate lithium metal content in gram (g):		

7. Physical description of cell / battery

Li-Ion Cuboid

LITHIUM CELL/BATTERY TEST SUMMARY

IN ACCORDANCE WITH SUB-SECTION 38.3
OF MANUAL OF TESTS AND CRITERIA



Name of cell/battery (taken from field 1)
74Wh Powerbank-20000mAh-PB320PD 74Wh

8. Model numbers
1700-0147

TESTS AND RESULTS

9. List of tests conducted and results - Mark N/A, pass or fail with an "•"	N/A	pass	fail
T1 - Altitude simulation	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
T2 - Thermal Test	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
T3 - Vibration	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
T4 - Shock	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
T5 - External Short Circuit	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
T6 - Impact / Crush	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
T7 - Overcharge	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
T8 - Forced Discharge	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>
	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

10. Reference to assembled battery testing requirements		
	N/A	<input type="text"/>

11. Reference to the revised edition of the Manual of Tests and Criteria used and to amendments thereto
ST-SG-AC10-11-Rev7-38.3

12. The manufacture of the cell / battery is in accordance with the documented quality management system as required by the regulations.

13. Place, Date	14. Title, Surname, First name	15. Company stamp and signature
Assamstadt	Testzentrum i.A. Gehring Klaus	Klaus Gehring <small>Digital unterschrieben von Klaus Gehring Datum: 2024.04.02 09:40:19 +02'00'</small>